

## EC-CERTIFICATE OF CONFORMITY

**Certificate No: 0809 - CPD - 0610**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the

**Panic exit devices, types PE480 and PE580 operated by horizontal bar PBE001, panic exit devices PE490 operated by horizontal bar PBE003 and panic exit devices PE590 operated by horizontal bar PBE002**

with the property profile:

3	7	6	1	1	3	3	2	A
---	---	---	---	---	---	---	---	---

presented also on page 2

placed on the market by

**Abloy Oy**

**Wahlforssinkatu 20**

**FIN-80101 Joensuu**

and produced in the factories

**Abloy Oy, FIN-80101 Joensuu**

are submitted to the manufacturer's factory production control, including continuous testing. The initial type-testing of the products, the inspection of the factories and the factory production controls, which are under continuous surveillance, have been performed. This certificate attests that the provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**EN 1125:1997/A1:2001**

were applied and that the the manufacturer's factory production controls and products and their properties mentioned on page 2 fulfil the requirements in Annex ZA of the standard EN 179:1997/A1:2001

This certificate was first issued on 2008-05-26 and remains valid as long as the conditions presented in the harmonised standard are fulfilled and the harmonised standard is not modified significantly or the manufacturing conditions in the factories or the FPC itself or existing contracts are not modified significantly.

Espoo 26.5 .2008



Liisa Rautiainen



Jarmo Ruohomäki



Assessment Manager

Senior Research Scientist

<b>Product</b>	<b>Property</b>	<b>Grade, category or type</b>
Locks PE480 and PE580 with bars PBE001 Locks PE490 with bars PBE003 and locks PE590 with bars PBE002	Category of use	Grade 3
	Durability	Grade 7 (200 000 test cycles)
	Door mass	Grade 6 (200 kg)
	Suitability for use on fire/smoke doors	Grade 1
	Safety	Grade 1
	Corrosion resistance	Grade 3 (high resistance)
	Security	Grade 3
	Projection of operating element	Category 2 (low projection, less than 100 mm)
	Type of operation	Type A (push bar operation)